

DATE	METER READING	DAILY DISCHARGE	TEMP	AIR	ALUM	TPS/STRIP ph READING WEEKLY	CHLORINE READING WEEKLY (mg/L)	EFFLUENT COLOUR	EFFLUENT ODOUR	FILTER CLEANED	CHLORINE CHANGED	COMMENTS	SIGNED TESTER
1/08/2023	17954	3						Yes	No	Yes	No		B.Boots
2/08/2023	17954	0						Yes	No	No	No	Nothing Pumped	B.Boots
3/08/2023	17959	5						Yes	No	Yes	No		B.Boots
4/08/2023	17962	3						Yes	No	Yes	No		B.Boots
5/08/2023	17966	4						Yes	No	Yes	No		B.Boots
6/08/2023	17969	3						Yes	No	Yes	No		B.Boots
7/08/2023	17969	0	17.3	11.2		7.0	0.67	Yes	No	Yes	No		B.Boots
8/08/2023	17984	0						Yes	No	Yes	Yes	changed chl & Alum Sol.	B.Boots
9/08/2023	17984	15						Yes	No	Yes	No		B.Boots
10/08/2023	18003	19						Yes	No	Yes	No		B.Boots
11/08/2023	18021	18						Yes	No	Yes	No		B.Boots
12/08/2023	18045	24						Yes	No	Yes	No		B.Boots
13/08/2023	18070	35						Yes	No	Yes	No		B.Boots
14/08/2023	18083	13						Yes	No	Yes	No		B.Boots
15/08/2023	18089	6						Yes	No	Yes	Yes	CHANGE CHL / PUMP NOT WORKING ON MANUAL	B.Boots
16/08/2023	18098	9	17.1	12.1		7.2	0.94	Yes	No	Yes	No		B.Boots
17/08/2023	18121	23						Yes	No	Yes	Yes	ALUM SOLF / CHANGED	B.Boots
18/08/2023	18123	2						Yes	No	Yes	No		B.Boots
19/08/2023	18125	2						Yes	No	Yes	No		B.Boots
20/08/2023	18129	4						Yes	No	Yes	No		B.Boots
21/08/2023	18132	3						Yes	No	Yes	No		B.Boots
22/08/2023	18159	27						Yes	No	Yes	Yes	CHANGED CHL	B.Boots
23/08/2023	18175	16	17.2	11.4		6.2	0.2108	Yes	No	Yes	No		B.Boots
25/08/2023	18175	0						Yes	No	Yes	No		B.Boots
26/08/2023	18179	4						OK	No	Yes	No		B.Boots
27/08/2023	18184	5						OK	No	Yes	No		B.Boots
28/08/2023	18199	5						Yes	No	Yes	Yes	CHANGED CHL	B.Boots
29/08/2023	18102	3						Yes	No	Yes	No		B.Boots
30/08/2023	18110	8						Yes	No	Yes	No		B.Boots
31/08/2023	18115	5	17.2	11.8		6.5	1.27	Yes	No	Yes	No		B.Boots

17966

PUMP
FIXED