

EPA DISCHARGE SHEET

Apr-24

DATE	METER READING	DAILY DISCHARGE	TEMP	AIR	ALUM	TPS/STRIP ph READING WEEKLY	CHLORINE READING (mg/L)	EFFLUENT COLOUR	EFFLUENT ODOUR	FILTER CLEANED	CHLORINE CHANGED	COMME NTS	SIGNED TESTER
14.24	21815	30						OK	OK	Yes	Yes	OK	OK
24.24	21343	28						OK	OK	Yes	No	OK	OK
34.24	21819	19						OK	OK	Yes	No	OK	OK
44.24	21370	8						OK	OK	Yes	Yes	OK	OK
54.24	21396	26	26°	2.37		7.2	0.5	OK	OK	Yes	No	OK	OK
64.24	21426	30						OK	OK	Yes	Yes	OK	OK
74.24	21456	30						OK	OK	Yes	Yes	OK	OK
84.24	21479	23						OK	OK	Yes	Yes	OK	OK
94.24	21506	27						OK	OK	Yes	No	OK	OK
104.24	21514	8						OK	OK	Yes	No	OK	OK
114.24	21544	30						OK	OK	Yes	No	OK	OK
124.24	21565	21						OK	OK	Yes	No	OK	OK
134.24	21590	25	23°	6.47		6.8	0.5	OK	OK	Yes	Yes	OK	OK
144.24	21615	25						OK	OK	Yes	No	OK	OK
154.24	21634	19						OK	OK	Yes	No	OK	OK
164.24	21654	20						OK	OK	Yes	No	OK	OK
174.24	21663	9						OK	OK	Yes	Yes	OK	OK
184.24	21672	9						OK	OK	Yes	Yes	OK	OK
184.24	21681	9						OK	OK	Yes	No	OK	OK
194.24	21711	30	24°	4.48		7.0	0.5	OK	OK	Yes	No	OK	OK
204.24	21741	30						OK	OK	Yes	No	OK	OK
214.24	21771	30						OK	OK	Yes	No	OK	OK
224.24	21780	9						OK	OK	Yes	Yes	OK	OK
234.24	21804	24						OK	OK	Yes	Yes	OK	OK
244.24	21807	3						OK	OK	Yes	Yes	OK	OK
254.24	21818	11						OK	OK	Yes	No	OK	OK
264.24	21825	7	22.2°	0.18		7.5	0.5	OK	OK	Yes	Yes	OK	OK
274.24	21840	15						OK	OK	Yes	No	OK	OK
284.24	21844	4						OK	OK	Yes	Yes	OK	OK
294.24	21853	13						OK	OK	Yes	Yes	OK	OK
304.24	21857	0						OK	OK	Yes	Yes	OK	OK